

YASKAWA Energy-Saving Unit


Power Regenerative Converter (K5=0)

D1000

200 V Class, 5.0 to 130 kW 400 V Class, 5.0 to 630 kW



Increase Your Power!



D1000 makes the most of AC drives to help you save more electricity in your equipment.

D1000


Energy-Saving
Triangle


AC Drive

Motor

Reuse the Previously Wasted Energy with a New W









RoHS compliant

Restriction of Hazardous Substances Directive is designated for use in Asia (Region code: T).

CONTENTS

Features

Application Examples

6

Applicable Models

7

Standard Specifications

8

Selecting the Capacity

10

Connection Diagram

11

Terminal Functions

16

Dimensions

18

Fully-Enclosed Design

22

Peripheral Devices and Options

24

Application Notes

30

Global Service Network

33


Let us help you improve the quality of your power.

Save More Energy

Save More Electricity with Power Regeneration

Combined with drives or servo systems, D1000 lets you effectively use energy by returning regenerative energy to the power supply.

Return Electricity with Power Regeneration



Reduce Wasteful Heat Loss


You can greatly reduce heat loss from power supply facilities caused by harmonics.



Connect Multiple Units

Save Energy with Regenerative Energy

In equipment that uses many drives or many servos, you can save energy by using all of the regenerative energy that you used to waste as the energy for other equipment.



Supply Stable DC Voltages

You can supply a stable DC voltage to drives and servo systems without being influenced by fluctuations in the input AC voltage.

Energy Savings That You Can See

Visualizing Savings in Electricity

You can use analog outputs and communications networks to easily and visually monitor all sorts of data.

Operation is as easy as for a Yaskawa 1000-series AC drive.




Solve Your Harmonics Issues

Compliance with Harmonic Suppression Guidelines

No Power Supply Harmonics

There are no power supply harmonics (K₅=0) and input power supply current waveform distortion is greatly reduced.

You can comply with harmonic suppression guidelines. You do not need a separate harmonic compensator to reduce harmonics to the same degree as an active filter. ● Input Power Supply Current Waveform Comparison



Power factor: **Approx. 0.7**



Small power supply current distortion rate.

Power factor: Approx. 1.0


Condition: Rated load.

Downsize Power Supply Equipment

Improved Power Factor

Reduce costs

Power supply power factor 1 control* and sinusoidal PWM control enable downsizing power supply facilities, including power cables and power receiving equipment, which greatly reduces facilities costs. By improving the power factor, you can expand equipment without increasing the capacity of existing power supply facilities.



*: Power supply power factor 1 control: Control in which the power supply phase voltage and power supply current are in the same phase (power factor of 1).

Let Us Meet Your Needs

Reduce Your Maintenance Costs

Long Life Performance

Ten Years of Durable Performance

Cooling fans, capacitors, and relays have been carefully selected and designed for a life expectancy of up to ten years.*

*: Assumes the drive is running continuously for 24 hours a day at 80% load with an ambient temperature of 40°C.

Performance Life Monitors

The D1000 is equipped with performance life monitors that notify the user of part wear and maintenance periods to prevent problems before they occur.

●The D1000 outputs a signal to the control device indicating components may need to be replaced



Operator Display	Corresponding Component
LT-1	Cooling fan
LT-2	Capacitors
LT-3	Inrush prevention relay

Easy Maintenance

Terminal Board with a Parameter Backup Function

The terminal block's ability to save parameter setting data makes it a breeze to get the application back online in the event of a failure requiring unit replacement.




●Terminal Block

Parameter

	Setting
b1-02	2
d8-01	680
H3-02	10
	d8-01

Engineering Tool DriveWizard Plus



· An indispensable tool for D1000 setup and maintenance. Edit parameters, access all monitors, create customized operation sequences, and observe D1000 performance with the oscilloscope function.

Parameter Copy Function

- All standard models are equipped with a Parameter Copy function using the keypad that allows parameter settings to be easily copied from the drive or uploaded for quick setup.
- A USB Copy Unit is also available as an even faster, more convenient way to back up settings and instantly program the drive.

Global Standards

We Support Global Business

O Compliance with Global Standards



RoHS compliant


Restriction of Hazardous Substances Directive

Note: The model CIMR-DT (1A 10101010) that bears the \$\mathbb{K}\$ mark conforms to

Korean Radio Waves Act and is designated for use in Asia (Region code: T).

Support for Field Networks

RS-422/RS-485 communications capability with the MEMOBUS/Modbus protocol is a standard feature. And you can mount communications options cards to enable using the main open field networks.




* : Available soon.


Greater Downsizing

More Compact and Less Wiring

Modules for peripheral devices, such as reactors, enable downsizing and reduce wiring. What you achieve is more compact equipment.

Comparison with Previous System (for 400 V, 20 kW)














Multiple Drive Connection





















Applicable Models

The following AC drives and AC Servo drives are recommended. The D1000 can be connected to existing products.



High performance vector control A1000



Compact vector control V1000



Compact V/f control J1000



High-function fully vector control Varispeed G7



Elevator applications L1000A



AC servo drives $\Sigma ext{-V}$ SERIES

Standard Specifications

Standard Specifications



D1000 Energy-saving Unit

Volta	age					200 V	Class									400 V	Class					
Mod	Model CIMR-DA (ACCULATE NO. 0005 0010 0020 0030 0050 0065 0090 0130									0130	0005	0010	0020	0030	0040	0060	0100	0130	0185	0270	0370	0630
Max.	Applicable Motor C	apacity kW	3.7	7.5	15	22	37	55	75	110	3.7	7.5	15	22	30	45	75	110	160	220	315	560
	Rated Output Cap	acity*2 kW	5	10	20	30	50	65	90	130	5	10	20	30	40	60	100	130	185	270	370	630
ing	Rated Output Cur	rent (DC) A	15	30	61	91	152	197	273	394	8	15	30	45	61	91	152	197	280	409	561	955
Rating	Rated Input Curr	ent (AC) A	15	29	57	83	140	200	270	400	8	16	30	43	58	86	145	210	300	410	560	1040
	Rated Outpu	ut Voltage				330	Vdc									660	Vdc					
=	Rated Voltage/Rat	ed Frequency			200 to	240 V	ac 50/	60 Hz							380 to	480 V	ac 50/	′60 Hz				
Input	Allowable Voltag	e Fluctuation	-15 to	+10%	ó																	
_	Allowable Frequen	cy Fluctuation	±2%																			
SS	Control Me	thod	Sine-v	vave P	WM co	ntrol																
erist	Input Power	r Factor		power	factor of	of 0.99	min. (fo	or rated	l opera	tion)												
acte	Output Voltage	e Accuracy	±5%																			
har	Overload P	rotection	Unit s	tops af	ter 60	s at 150	0% of r	ated or	utput c	urrent o	or after	3 s at 2	200%	of rated	loutpu	t curre	nt.					
Control Characteristics	Voltage Refere					300 to 3	360 Vd								(600 to	730 Vd					
Jut	Carrier Free	· ·			Hz			4 k						Hz				4 kHz			2 kHz	
ŏ	Main Control					an on/off				inal Bloc	k with P	arameter	Backup	Function	n, MEMO)BUS/M	odbus C	omm. (R	S-422/RS	S-485 m	ax, 115.2	2 kbps)
	Momentary Overcui					out curr			50%.													
	Fuse burno	ut	<u> </u>	Operation stops if the fuse burns out.																		
				Operation stops after 60 s at 150% of rated output current.																		
စ္	Overloads			Operation stops after 3 s at 200% of rated output current.																		
tior	0 11	<u> </u>		(electrical operation and regeneration) Stops when DC bus voltage exceeds approx. 410 Vdc Stops when DC bus voltage exceeds approx. 820 Vdc																		
l oun	Overvoltage	Output	<u> </u>																			
L L	Protection	Input				voltage													rox. 55			
Protection Functions	Undervoltage	Output				voltage													prox. 3			
ote	Protection	Input	<u> </u>			oltage f							Stops	wnen	nput v	onage i	alls be	iow app	orox. 30	JU vac		
٦	Momentary P Power Supply Fre					after Mo						od inni	ıt frogu	IODOV								
	Heatsink Overhe	<u> </u>	<u> </u>		therm		ation of	±0 ⊓Z	OI IIIOI	e iroin	the rai	eu iripi	ut irequ	iency.								
	Ground Fault P					onic cir	ouit															
	Charge LEI					s lit unt		iie hae	fallen l	nelow s	nnroy	50 V										
	Area of Use				TOTTIAIT	3 III UIII	11 00 0	us nas	Talleri	JCIOW E	фріох.	00 V										
	Ambient Ten			Indoors - 10 to +50°C (IP00/IP20/Open Type enclosure)																		
τ	Humidity	inportation	95% RH or less (no condensation)																			
Environment	- rannany			(2A0005 to 2A0050, 4A0005 to 4A0100) 10 to 20 Hz : 9.8 m/s², 20 to 55 Hz : 5.9 m/s²																		
loi	Shock		(2A0065 to 2A0130, 4A0130 to 4A0370) 10 to 20 Hz : 9.8 m/s², 20 to 55 Hz : 2.0 m/s²																			
l N	oo					tz : 5.9						0,20			, 0							
	Storage Ten	nperature	_			t-term t																
	Altitude	,				(deratir						n to 30	000 m)									
Prot	ection Desig	ın				oe encl							/									
_	ety Standard							0-3														
	,	Standard UL508C, IEC61800-5-1, IEC61800-3																				

- *1: This number indicates the voltage class (2: 200 V class, 4: 400 V class).
- *2 : For the 200 V class, rated output capacity is calculated with a rated output voltage of 220 V. For the 400 V class, values are given for an input voltage of 440 V.
- *3 : Protection may not be provided under the following conditions as the motor windings are grounded internally during run:

 Low resistance to ground from the drive cable or terminal block.

 Drive already has a short-circuit when the power is turned on.

 Note: You must install a harmonic filter module and input AC reactor 1 for a D1000 of 5 to 185 kW.

You must install a reactor for the harmonic filter, a capacitor for the harmonic filter, and input AC reactors 1 and 2 for a D1000 of 270 to 630 kW.






D1000 Standard Configuration Devices

Voltage					200) V									4	100 V					
Model CIMR-	DA*:A	0005	0010	0020	0030	0050	0065	0090	0130	0005	0010	0020	0030	0040	0060	0100	0130	0185	0270	0370	0630
Harmonic	Rated	15	29	57	83	140	200	270	400	8	16	30	43	58	86	145	210	300			
Filter Module	Current	15	29	37	03	140	200	270	400	0	10	30	43	56	00	145	210	300		_	_
Input AC	Rated Current A	15	29	57	83	140	200	270	400	8	16	30	43	58	86	145	210	300	410	560	560
Reactor 1	Inductance mH	2.45	1.27	0.64	0.44	0.26	0.18	0.14	0.09	9.19	4.59	2.45	1.71	1.27	0.85	0.51	0.35	0.25	0.18	0.13	0.13
Input AC	Rated Current A		_	_	_	_									_	_	_	_	410	560	1140
Reactor 2	Inductance mH																		0.06	0.05	0.02
Reactor for	Rated Current A			_		_		_								_	_		64	87	177
Harmonic Filter	Inductance mH																		0.022	0.0158	0.0079
Condenser for	Rated _{µF}			_		_												_	290	402	800
Harmonic Filter	Capacity ^{μ1}																		290	402	800

 \bigstar : This number indicates the voltage class (2: 200 V class, 4: 400 V class). Note: CIMR-DA:::4A0630 requires two units of input AC reactor 1.



Selecting the Capacity / Connection Diagram

D1000 Capacity Selection


Easy Selection The recommended D1000 models are given in the following table when one drive is connected.

200 V Class															
Motor Capacity	(kW)	3.7	5.5	7.5	11	15	18.5	22	30	37	45	55	75	90	110
Drive Capacity ((kW)	or less	3.3	7.5	- ' '	13	10.5	22	30	37	40	33	7	90	110
	0005	•	_	_	_	_	_	_	_	_	_	_	_	_	- 1
	0010	_	•	•	_	_	_	_	_	_	_	_	_	_	-
D4000 M 1 1	0020	_	_	_	•	•	_	_	_	_	_	_	_	_	-
D1000 Model CIMRDA2A	0030	_	_	_	_	_	•	•	_	_	_	_	_	_	-
CIIVINDAZA	0050	_	_	_	_	_	_	_	•	•	_	_	_	_	-
1-11-11-11	0065	_	_	_	_	_	_	_	_	_	•	•	_	_	-
	0090	_	_	_	_	_	_	_	_	_	_	_	•	_	-
	0130	_	_	_	_	_	_	_	_	_	_	_	_	•	•

400 V Class																						
Motor Capacity		3.7	5.5	7.5	11	15	18.5	22	30	37	45	55	75	90	110	132	160	185	220	315	450	560
Drive Capacity	kW)	or less	0.0	7.0		10	10.0		00	0,	40	00	70	- 50	110	102	100	100	220	010	400	
	0005	•	_	-	_	-	_	_	_	_	-	-	_	_	_	-	_	_	-	_	-	-
	0010	-	•	•	-	_	_	_	_	-	_	_	_	_	_	-	_	_	_	_	_	-
	0020	-	-	-	•	•	_	_	_	-	-	-	_	_	_	-	-	_	_	-	_	-
	0030	-	-	-	_	-	•	•	-	-	_	_	_	_	-	-	_	-	-	_	_	-
	0040	-	-	-	_	_	_	-	•	-	_	_	_	_	_	-	_	-	-	_	_	-
D1000 Model	0060	-	-	-	_	_	_	_	-	•	•	_	_	_	-	-	_	-	-	_	_	-
CIMRDA4A	0100	-	-	-	_	_	_	_	_	_	_	•	•	_	_	-	_	_	_	_	_	-
1-11-11-11-1	0130	-	-	-	_	_	_	_	_	-	_	_	_	•	•	-	_	_	_	_	_	-
	0185	-	-	-	_	_	_	_	_	-	_	_	_	_	_	•	•	_	_	_	_	-
	0270	-	-	-	_	_	_	_	_	-	_	_	_	_	_	_	_	•	•	_	_	-
	0370	-	-	-	_	_	_	_	_	-	_	_	_	_	_	-	_	_	_	•	_	-
	0630	_	-	_	_	-	_	-	_	-	-	-	-	-	_	_	-	_	_	-	•	•

Optimum Selection

If more than one drive is connected or for a more detailed selection, use the flowchart to select D1000 capacity.



Note: 1. If the interphase voltage imbalance ratio of the power source exceeds 2%, use a unit with a frame size that is one higher than otherwise necessary. You can calculate the interphase voltage imbalance ratio of the power source with the following formula. (Conforms to IEC 61800-3 (5.2.3).)

$$\frac{.}{\text{Interphase imbalance ratio (\%)}} = \frac{\frac{.}{\text{Maximum voltage}} - \frac{.}{\text{Minimum voltage}}}{\frac{.}{\text{Three-phase average voltage}}} \times 67$$

 $2.\ Do\ not\ determine\ combinations\ based\ on\ the\ drive\ model\ numbers\ and\ D1000\ model\ numbers.$


Selecting the Power Supply Capacity

Connect a power supply with a capacity (kVA) that is larger than the rated input capacity (kW) of the unit. If a power supply with a capacity that is smaller than the rated input capacity is connected, an operating fault may occur. If you need to connect a power supply with a capacity that is smaller than the rated input capacity, consult with your Yaskawa representative or the nearest Yaskawa sales office.

Power Supply Capacity (kVA) ≥ Rated Input Capacity (kW)

Standard Connection Diagram

Model: CIMR-DA2A0005 to 0130, CIMR-DA4A0005 to 0185



- *1: When a noise filter is attached on D1000 power supply side, use a noise filter of the reactor type (without a capacitor) such as FINEMET(R) zero-phase reactor, and attach it after the MCCB at the power supply side. Do not use a capacitor-built-in type noise filter since the harmonic components may overheat or damage the capacitor.
- *2: The wiring between the input AC reactor and D1000 must be within 10 m.
- *3 : Always use the specified AC reactor and harmonic filter (harmonic filter module) to avoid abnormal operations.
- *4: The DC current bus bar wiring between D1000 and the drive must be within 5 m.
- *5: When installing a breaker or contactor on the D1000 side for an emergency shutoff, confirm that the CHARGE indicators on the drive and D1000 are not lit before closing the breaker or contactor on the D1000 output (DC) side. If the power supply is turned on while there is a voltage charge, an overcurrent will flow and the device may be damaged. Always confirm that the breaker or contactor on the D1000 output (DC) side is turned on before applying power to the D1000.
- *6: Make sure that the D1000 starts before the drive when the power supply is turned on. Stop the devices in the following order before you turn off the power supply: the drive, the motor, and then D1000. A fault may occur if you use the drive without operating the unit or if you turn off the power supply while the D1000 is operating.
- *7 : Do not connect a power supply to the drive's AC power supply terminals (R/L1, S/L2, and T/L3).
- *8: This figure shows an example of a sequence input to S1 through S8 using a non-powered relay or an NPN transistor (0 V common/sink mode: default). Set either sinking or sourcing with the sinking/sourcing jumpers (S3).
- *9 : Monitor outputs work with devices such as analog frequency meters, ammeters, voltmeters, and wattmeters. Do not use these outputs in a feedback loop.




E(G)	FI	M	Α	С	Α	М	Р	1	Р	2	Ρ	С	S	С			
	S	С	Α	.1	Α	2	Α	3	+	V	Α	С	_	٧		MA	МВ	МС
S	1	S	2	S	3	S	4	s	5	S	6	s	7	S	8	M1	M2	E(G)

Connection Diagram (continued)


Standard Connection Diagram

Model: CIMR-DA4A0270, 4A0370



- *1: When a noise filter is attached on D1000 power supply side, use a noise filter of the reactor type (without a capacitor) such as FINEMET zero-phase reactor, and attach it after the MCCB at the power supply side. Do not use a capacitor-built-in type noise filter since the harmonic components may overheat or damage the capacitor.
- *2: The wiring between the input AC reactor and D1000 must be within 10 m.
- *3 : Always use the specified AC reactor and harmonic filter (harmonic filter module) to avoid abnormal operations.
- $st\!4$: The DC current bus bar wiring between D1000 and the drive must be within 5 m.
- *5: When installing a breaker or contactor on the D1000 side for an emergency shutoff, confirm that the CHARGE indicators on the drive and D1000 are not lit before closing the breaker or contactor on the D1000 output (DC) side. If the power supply is turned on while there is a voltage charge, an overcurrent will flow and the device may be damaged. Always confirm that the breaker or contactor on the D1000 output (DC) side is turned on before applying power to the D1000.
- *6: Make sure that the D1000 starts before the drive when the power supply is turned on. Stop the devices in the following order before you turn off the power supply: the drive, the motor, and then D1000. A fault may occur if you use the drive without operating the unit or if you turn off the power supply while the D1000 is operating.
- *7 : Do not connect a power supply to the drive's AC power supply terminals (R/L1, S/L2, and T/L3).
- *8: This figure shows an example of a sequence input to S1 through S8 using a non-powered relay or an NPN transistor (0 V common/sink mode: default). Set either sinking or sourcing with the sinking/sourcing jumpers (S3).
- *9: Monitor outputs work with devices such as analog frequency meters, ammeters, voltmeters, and wattmeters. Do not use these outputs in a feedback loop.

Model: CIMR-DA4A0630




- *1: When a noise filter is attached on D1000 power supply side, use a noise filter of the reactor type (without a capacitor) such as FINEMET zero-phase reactor, and attach it after the MCCB at the power supply side. Do not use a capacitor-built-in type noise filter since the harmonic components may overheat or damage the capacitor.
- *2: The wiring between the input AC reactor and D1000 must be within 10 m.
- *3 : Always use the specified AC reactor and harmonic filter (harmonic filter module) to avoid abnormal operations.
- *4: The DC current bus bar wiring between D1000 and the drive must be within 5 m.
- *5: When installing a breaker or contactor on the D1000 side for an emergency shutoff, confirm that the CHARGE indicators on the drive and D1000 are not lit before closing the breaker or contactor on the D1000 output (DC) side. If the power supply is turned on while there is a voltage charge, an overcurrent will flow and the device may be damaged. Always confirm that the breaker or contactor on the D1000 output (DC) side is turned on before applying power to the D1000.
- ★6: Make sure that the D1000 starts before the drive when the power supply is turned on. Stop the devices in the following order before you turn off the power supply: the drive, the motor, and then D1000. A fault may occur if you use the drive without operating the unit or if you turn off the power supply while the D1000 is operating.
- *7: Do not connect a power supply to the drive's AC power supply terminals (R/L1, S/L2, and T/L3).
- *8 : This figure shows an example of a sequence input to S1 through S8 using a non-powered relay or an NPN transistor (0 V common/sink mode: default). Set either sinking or sourcing with the sinking/sourcing jumpers (S3).
- *9 : Monitor outputs work with devices such as analog frequency meters, ammeters, voltmeters, and wattmeters. Do not use these outputs in a feedback loop.

Connection Diagram (continued)


Drive Connections

A1000 Connection Example (Model: CIMR-DA4A0185)



- *1: When a noise filter is attached on D1000 power supply side, use a noise filter of the reactor type (without a capacitor) such as FINEMET zero-phase reactor, and attach it after the MCCB at the power supply side. Do not use a capacitor-built-in type noise filter since the harmonic components may overheat or damage the capacitor.
- *2: The wiring between the input AC reactor and D1000 must be within 10 m.
- *3 : Always use the specified AC reactor and harmonic filter (harmonic filter module) to avoid abnormal operations.
- *4: The DC current bus bar wiring between D1000 and the drive must be within 5 m.
- *5: When installing a breaker or contactor on the D1000 side for an emergency shutoff, confirm that the CHARGE indicators on the drive and D1000 are not lit before closing the breaker or contactor on the D1000 output (DC) side. If the power supply is turned on while there is a voltage charge, an overcurrent will flow and the device may be damaged. Always confirm that the breaker or contactor on the D1000 output (DC) side is turned on before applying power to the D1000.
- *6: Make sure that the D1000 starts before the drive when the power supply is turned on. Stop the devices in the following order before you turn off the power supply: the drive, the motor, and then D1000. A fault may occur if you use the drive without operating the unit or if you turn off the power supply while the D1000 is operating.
- *7 : Do not connect a power supply to the drive's AC power supply terminals (R/L1, S/L2, and T/L3).
- *8: This figure shows an example of a sequence input to S1 through S8 using a non-powered relay or an NPN transistor (0 V common/sink mode: default). Set either sinking or sourcing with the sinking/sourcing jumpers (S3).
- \$9: Refer to Interlocks on page 30 for information on an interlock with the drive.

Varispeed G7 Connection Example (Model: CIMR-DA4A0185)




- ★1: Do not connect a power supply to the Varispeed G7's AC power supply terminals (R/L1, S/L2, and T/L3).
- *2 : For the cooling fan terminals r' ℓ_1 and ℓ_2 / ℓ_2 on 200 V class Varispeed G7 models for 30 to 75 kW, remove the jumper leads from between ℓ_1 and R/L1 and from between ℓ_2 / ℓ_2 and S/L2. Take the power supply from the primary power supply line to the unit.
- *3 : Always use the specified AC reactor and harmonic filter module. Operation may not be correct if non-specified devices are used.
- *4: Sequence operation after the power supply is turned on so that the unit starts operation before the drive. Sequence stopping operation in the following order before you turn off the power supply: drive, motor, and then unit. A unit fault may occur if you operate the drive without operating the unit or turn off the power supply during unit operation.
- *5: For information on an interlock with the drive, refer to *Interlocks* on page 30.
- *6: If you install a noise filter on the power supply side of the unit, use a reactor-type noise filter (without a capacitor), such as a FINEMET zero phase reactor, and install it after the MCCB on the power supply side. Do not install a filter with a built-in capacitor. The harmonic components may cause the capacitor to overheat or may damage the capacitor.
- overheat or may damage the capacitor. *7: Do not use a line that is longer than 10 m to connect the input AC reactor and the unit.
- *8: Do not use a DC bus line that is longer than 5 m to connect the unit and drive.
- *9: When installing a breaker or contactor on the D1000 side for an emergency shutoff, confirm that the CHARGE indicators on the drive and D1000 are not lit before closing the breaker or contactor on the D1000 output (DC) side. If the power supply is turned on while there is a voltage charge, an overcurrent will flow and the device may be damaged. Always confirm that the breaker or contactor on the D1000 output (DC) side is turned on before applying power to the D1000.

Terminal Functions

Terminal Functions

D1000 Energy-saving Unit

Main Circuit Terminals




Control Circuit Input Terminals (200 V/400 V Class)

Terminal Type	Terminal	Terminal Name (Default Setting)	Function (Signal Level)
	S1	Multi-function selection input 1 (RUN-SB)	Photocoupler
	S2	Multi-function selection input 2 (STOP)	24 Vdc, 8 mA
	S3	Multi-function selection input 3 (External fault)	The factory setting is for Sinking Mode.
Multi-Function	S4	Multi-function selection input 4 (Fault reset)	Use the sinking/sourcing mode jumper (S3) to change
Digital Inputs	S5	Multi-function selection input 5 (Reserved)	the sinking/sourcing mode setting to select an internal or
Digital inputs	S6	Multi-function selection input 6 (Reserved)	external power supply.
	S7	Multi-function selection input 7 (Reserved)	For details, refer to Sinking/Sourcing Mode Switch, 3.9
	S8	Multi-function selection input 8 (External Baseblock)	Control I/O Connections in Installation Manual (Manual No.
	SC	Multi-function selection input common	TOEP C710656 04).
	+V	Analog reference input	10.5 Vdc (max allowable current 20 mA)
	-V	Analog reference input	-10.5 Vdc (max allowable current 20 mA)
	A1	Multi-function analog input 1 (Reserved)	$-$ 10 to +10 Vdc, 0 to 10 Vdc (input impedance: 20 k $\Omega)$
Analog Inputs	A2	Multi-function analog input 2 (Reserved)	-10 to +10 Vdc, 0 to 10 Vdc (input impedance: 20 k $\Omega)$ 4 to 20 mA, 0 to 20 mA (input impedance: 250 $\Omega)$ Voltage or current input must be selected by DIP switch S1 and H3-09.
	A3	Multi-function analog input 3 (Reserved)	-10 to $+10$ Vdc, 0 to 10 Vdc (input impedance: $20~k\Omega)$ Use DIP switch S4 on the terminal board to select between analog and PTC input.
	AC	Frequency reference common	0 V
	E (G)	Ground for shielded lines and option cards	_
	MA	N.O. output (Fault)	Relay output
Fault Relay	MB	N.C. output (Fault)	30 Vdc, 10 mA to 1 A
Output	MC	Fault output common	250 Vac, 10 mA to 1 A MB N.C. output Minimum load: 5 Vdc, 10 mA
Multi-Function	M1	Multi-function digital output (During run 1)	Default setting: During Run 1 The M1-M2 terminals close during operation.
Digital Output*1	M2	india-ranetion digital output (During run 1)	When the DC bus voltage reaches the reference value after the operation of the unit is started, the M1-M2 terminals close.
Multi-Function	P1	Photocoupler output 1 (During MC on)	Dispersion of the state of the
Photocoupler	P2	Photocoupler output 2 (Converter ready)	Photocoupler output*2 48 V, 2 to 50 mA
Output	PC	Photocoupler output common	70 V, 2 to 50 IIIA
	FM	Analog monitor output 1	-10 to +10 Vdc, or 0 to +10 Vdc
Monitor Output	AM	Analog monitor output 2	10 to 110 vac, or 0 to 110 vac
	AC	Monitor common	0 V

^{*1 :} Do not assign functions to terminals M1 and M2 that involve frequent switching, unless absolutely necessary, because doing so may shorten the relay performance life. The switching life is estimated at 200,000 times (1 A, resistive load).

^{*2 :} Connect a flywheel diode as shown when driving a reactive load such as a relay coil. The diode must be rated for use of a voltage higher than the circuit voltage.



Serial Communication Terminals (200 V/400 V Class)

		(======================================		
Type	No.	Signal Name	Function (S	signal Level)
	R+	Communications input (+)	MEMORIJO (M. III	RS-422/RS-485
MEMOBUS/	R-	Communications input (-)	MEMOBUS/Modbus communications: Use an RS-422 or RS-485 cable to connect	MEMOBUS/Modbus
Modbus	S+	Communications output (+)	the unit.	communications protocol
Communications*	S-	Communications output (-)	the unit.	115.2 kbps (max.)
	IG	Shield ground	0	V

^{★:} Enable the termination resistor in the last unit in a MEMOBUS/Modbus network by setting DIP switch S2 to the ON position.

D1000 Standard Configuration Devices [CIMR-DA2A0005 to 2A0130, CIMR-DA4A0005 to 4A0185]



Harmonic Filter Module

Terminal	Туре	Function
R/L1		
S/L2	Main circuit power supply inputs	These terminals are connected to the power supply.
T/L3		
r		These terminals are to detect the power supply voltage
4	Power supply voltage detection inputs	order and voltage levels.
t		order and voltage levels.
X		
Y	Harmonic filter module outputs	These terminals are connected to the input AC reactor 1.
Z		
		Grounding terminals
(1)	Grounding terminal	For 200 V class: 100 Ω or less
		For 400 V class: 10 Ω or less

Input AC Reactor 1

Terminal	Туре	Function
U		
V	Input AC reactor 1 inputs	These terminals connect to a harmonic filter module.
W		
X		
Y	Input AC reactor 1 outputs	These terminals connect to D1000.
Z		

[CIMR-DA4A0270 to 4A0630]

Input AC Reactor 1

Terminal	Туре	Function
V W	Input AC reactor 1 inputs	These terminals connect to the input AC reactor 2 and the reactor for the harmonic filter.
X Y Z	Input AC reactor 1 outputs	These terminals connect to D1000.

Input AC Reactor 2

input/to i	1040101 2	
Terminal	Туре	Function
U		
V	Input AC reactor 2 inputs	These terminals connect to the power supply.
W		
Х		These terminals connect to the input AC reactor 2 and
Y	Input AC reactor 2 outputs	the reactor for the harmonic filter.
Z		the reactor for the narmonic filter.

Reactor for Harmonic Filter

Terminal	Туре	Function
V W	Reactor inputs for harmonic filter	These terminals connect to the input AC reactor 1 and the input AC reactor 2.
X Y Z	Reactor outputs for harmonic filter	These terminals connect to the capacitor for the harmonic filter.

Capacitor for Harmonic Filter

	_	=
Terminal	Туре	Function
U		These terminals connect to the capacitor for the
V	Capacitor inputs for harmonic filter	harmonic filter.
W		marmonic niter.
		Grounding terminals
E	Grounding terminal	For 200 V class: 100 Ω or less
		For 400 V class: 10 Ω or less

D1000 Energy-saving Unit

Enclosures


Enclosures of standard products vary depending on the model. Refer to the table below.

Voltage Class				1	200 V	Class	3								400	V Cla	ass				
Model CIMR-DA	Model CIMR-DA:*:A:::::::::::::::::::::::::::::::::								0130	0005	0010	0020	0030	0040	0060	0100	0130	0185	0270	0370	0630
Rated Output Capa							65	90	130	5	10	20	30	40	60	100	130	185	270	370	630
Onan Chassis	pen-Chassis IP00 –								•		_						Stand	dard			
Open-Chassis	IP20	S	tanda	rd		Mad	e to c	rder		St	tanda	rd		N	lade t	o ord	er		Not	availal	ole

^{*:} This number indicates the voltage class (2: 200 V class, 4: 400 V class).

■Open-Chassis [IP00]

Dimensions (mm)




200 V Class

Model	Rated Output Capacity	Figure				D	imensio	ons (mn	n)				Weight	Cooling
CIMR-DA2A[[[[]]]]	kW	rigure	W	Н	D	W1	H1	H2	D1	t1	t2	d	(kg)	Cooling
0030	30		275	450	258	220	435	7.5	100	2.3	2.3	M6	20	
0050	50	_	325	550	283	260	535	7.5	110	2.3	2.3	IVIO	32	Fan
0065	65	'	450	705	330	325	680	12.5	130	3.2	3.2	M10	57	
0090	90		450	703	330	323	000	12.5	130	3.2	3.2	IVITO	61	cooled
0130	130	2	500	800	350	370	773	13	130	4.5	4.5	M12	85	

400 V Class

Model	Rated Output Capacity	Figure .				D	imensio	ons (mn	n)				Weight	Casling
CIMR-DA4A	kW	Figure	W	Н	D	W1	H1	H2	D1	t1	t2	d	(kg)	Cooling
0030	30		275	450	258	220	435	7.5	100	2.3	2.3	M6	21	
0040	40	4	213	430	200	220	433	7.5	100	2.3	2.3	IVIO	21	
0060	60		325	550	283	260	535	7.5	110	2.3	2.3	M6	34	
0100	100		323	550	203	200	535	7.5	110	2.3	2.3	IVIO	36	Fan
0130	130	2	500	800	350	370	773	13	130	4.5	4.5	M12	85	-
0185	185	2	300	800	330	370	113	13	130	4.5	4.5	IVITZ	65	cooled
0270	270	3	670	1140	370	440	1110	15	150	4.5	4.5	M12	183	
0370	370	٥	0/0	1140	3/0	440	1110	13	130	4.5	4.5	IVIIZ	194	
0630	630	4	1250	1380	370	1100	1345	15	150	4.5	4.5	M12	413	

■ Open-Chassis [IP20] Dimensions (mm)



200 V Class

Model	Rated Output Capacity	Figure					Di	mensi	ons (m	m)					Weight	Cooling
CIMR-DA2A[[#]#]	kW	rigure	W	Н	D	W1	H0	H1	H2	Н3	D1	t1	t2	d	(kg)	Cooling
0005	5	-1	180	300	187	160	_	284	8	_	75	5		M5	5	
0010	10	ı	100	300	107	100		204	0		73	J		IVIO	3	
0020	20	2	220	365	197	192	350	335	8	15	78	5	_	M6	8	
0030	30		279	515	258	220	450	435	7.5	65	100	2.3	2.3	M6	23	Fan
0050	50		329	730	283	260	550	535	7.5	180	110	2.3	2.3	M6	36	cooled
0065	65	3	456	960	330	325	705	680	12.5	255	130	3.2	3.2	M10	65	
0090	90		430	900	330	323	705	000	12.5	233	130	3.2	3.2	IVITO	69	
0130	130		504	1168	350	370	800	773	13	368	130	4.5	4.5	M12	95	

400 V Class

Model	Rated Output Capacity	Figure					Di	mensio	ons (m	m)					Weight	Cooling
CIMR-DA4A[[#]#]	kW	rigure	W	Н	D	W1	H0	H1	H2	НЗ	D1	t1	t2	d	(kg)	Cooling
0005	5	-1	180	300	187	160	_	284	8	_	75	5	_	M5	5	
0010	10	ı	100	300	107	100		204	0		75	5		IVIS	5	
0020	20	2	220	365	197	192	_	335	8	_	78	5	_	M6	8	
0030	30		279	515	258	220	450	435	7.5	65	100	2.3	2.3	M6	23	Fan
0040	40		219	313	236	220	450	433	7.5	03	100	2.3	2.3	IVIO	23	cooled
0060	60	3	329	730	283	260	550	535	7.5	180	110	2.3	2.3	M6	38	Cooled
0100	100	3	329	730	203	200	550	333	7.5	100	110	2.3	2.3	IVIO	40	
0130	130		504	1168	350	370	800	773	13	368	130	4.5	4.5	M12	95	
0185	185		504	1100	330	370	600	113	13	300	130	4.5	4.5	IVITZ	95	

Combinations of Standard Configuration Devices

Standard Configuration Devices

The standard configuration devices depend on D1000 model. Use the following table to select a combination.


Voltage Class				200 V	Class									400) V Cla	ss				
Model CIMR-DA: *: A: :::::::::	0005	0010	0020	0030	0050	0065	0090	0130	0005	0010	0020	0030	0040	0060	0100	0130	0185	0270	0370	0630
Harmonic Filter Module	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	_	_	_
Input AC Reactor 1	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•	•
Input AC Reactor 2	-	_	_	_	_	_	_	_	_	-	_	_	-	_	-	-	_	•	•	•
Reactor for Harmonic Filter	_	-	_	_	_	_	_	-	_	_	_	_	_	_	_	_	_	•	•	•
Condenser for Harmonic Filter	_	_	_	_	_	_	_	_	_	_	_	_	_	_	_	-	_	•	•	•

^{*:} This number indicates the voltage class (2: 200 V class, 4: 400 V class).

Input AC Reactor 1 (UZBA-B: for Input)

Select the reactor according to the capacity of D1000.








Figure 1

Figure 2

Figure 3

Input AC Reactor 1 200 V Class

Model	Code No.	Otv	Eiguro						D	imensi	ons (mn	n)						Weight
CIMR-DA2A	Code No.	Qty.	Figure	Α	В	B1	С	D	Е	F	Н	- 1	J	K	L	М	N	(kg)
0005	100-088-216		1	160	114	172	133	75	95	160	25	2.3	M6	10	7	M4	_	8.2
0010	100-088-217]	'	205	106	173	173	75	85	205	25	3.2	M6	10	7	M5	_	14
0020	100-088-218			268	146	241	275	150	115	220	40	6	M8	18	10	M6	15	28
0030	100-088-219] ,		268	161	260	290	150	131	220	40	6	M8	18	10	M8	15	38
0050	100-088-220] '	,	330	161	268	334	170	131	270	40	6	M10	22	12	M8	15	65
0065	100-088-221]	4	320	211	306	343	170	181	270	40	6	M10	22	12	M12	15	79
0090	100-088-222]		380	220	320	382	200	180	320	50	6	M12	27	15	M12	20	102
0130	100-088-223			445	240	386	436	240	200	420	50	6	M12	27	15	M12	20	164

400 V Class


Model	Code No.	Qty.	Figure						D	imensi	ons (mn	n)						Weight
CIMR-DA4A	Code No.	Qty.	rigure	Α	В	B1	С	D	Е	F	Н	- 1	J	K	L	М	N	(kg)
0005	100-088-224			160	104	162	133	75	85	160	25	2.3	M6	10	7	M4	_	7.1
0010	100-088-225		1	206	101	166	173	75	80	205	25	3.2	M6	10	7	M4	_	13
0020	100-088-226			240	126	210	212	150	106	240	25	3.2	M8	10	10	M6	_	26
0030	100-088-227			265	161	243	290	150	131	220	40	6	M8	18	10	M8	15	34
0040	100-088-228			268	176	272	285	150	146	220	40	6	M8	18	10	M8	15	44
0060	100-088-229	1		330	161	273	331	170	131	270	40	6	M10	22	12	M8	15	56
0100	100-088-230			320	211	309	366	170	181	270	40	6	M10	22	12	M8	15	87
0130	100-088-231		2	385	235	330	382	200	195	320	50	6	M12	27	15	M12	20	122
0185	100-088-232			450	240	335	424	240	200	420	50	6	M12	27	15	M12	20	150
0270	100-088-233			510	300	410	482	245	250	490	65	6	M12	27	15	M12	25	222
0370	100-088-234			560	320	435	549	300	260	530	75	9	M12	27	15	M12	30	293
0630	100-088-234	2		560	320	435	549	300	260	530	75	9	M12	27	15	M12	30	293

Input AC Reactor 2 400 V Class


Model	Code No.	04	Fi						D	imensio	ons (mn	n)						Weight
CIMR-DA4A	Code No.	Qty.	Figure	Α	В	B1	С	D	Е	F	Н	- 1	J	K	L	M	N	(kg)
0270	100-088-235		_	330	176	325	326	170	146	270	40	6	M10	22	12	M12	15	60
0370	100-088-236	1	2	385	220	350	382	200	180	320	50	6	M12	27	15	M12	20	102
0630	100-088-237	1	3	452	375	130	545	302	335	_	50	6	M12	27	15	M12	-	172


Harmonic Filter Module


Select the appropriate harmonic filter modules according to D1000 models.




Dimensions (mm)












Figure 6

200 V Class

Model	Harmonic F	ilter Module	Eiguro			Dime	nsions	(mm)			Weight
CIMR-DA2A	Model	Code No.	Figure	Α	В	С	D	Е	F	Н	(kg)
0005	EUJ710800	100-091-249	3	209	285	176	160	240	39	M6	6.5
0010	EUJ710810	100-091-250	3	209	295	184	160	250	39	M6	9
0020	EUJ710820	100-091-251	4	232	301	265	203	247	44	M8	14
0030	EUJ710830	100-091-252	5	260	305	281	220	256	39	M8	16
0050	EUJ710840	100-091-253	6	290	355	348	250	314	30	M10	27
0065	EUJ710850	100-091-254	7	290	352	350	254	314	27	M10	38
0090	EUJ710860	100-091-255	7	290	352	387	254	314	27	M10	43
0130	EUJ710871	100-110-486	8	350	380	500	290	350	19	M10	62

Condenser for Harmonic Filter Dimensions (mm)




Figure 9

400 V Class

Model	Harmonic F	ilter Module	Figure			Dime	nsions	(mm)			Weight
CIMR-DA4A	Model	Code No.	rigure	Α	В	С	D	Е	F	Н	(kg)
0005	EUJ710880	100-091-257	3	209	285	176	160	240	39	M6	7
0010	EUJ710890	100-091-258	3	209	295	178	160	250	39	M6	9
0020	EUJ710900	100-091-259	4	232	301	265	203	247	44	M8	15
0030	EUJ710910	100-091-260	5	260	305	293	220	256	39	M8	17
0040	EUJ710920	100-091-261	5	260	305	293	220	256	39	M8	19
0060	EUJ710930	100-091-262	6	290	355	348	250	314	30	M10	27
0100	EUJ710940	100-091-263	6	290	355	385	250	314	30	M10	39
0130	EUJ710951	100-110-487	8	350	380	500	290	350	19	M10	64
0185	EUJ710961	100-110-488	8	350	380	500	290	344	25	M10	73


Reactor for Harmonic Filter, Condenser for Harmonic Filter

Reactor for Harmonic Filter

Model CIMR-DA4A	Code No.	Figure						Dimer	nsions	(mm))					Weight (kg)
Clivin-DA4A			Α	В	B1	С	D	Е	F	Н	-1	J	K	L	М	(Ng)
0270	100-088-238		160	104	147	135	75	85	160	25	2.3	M6	10	7	M8	6.3
0370	100-088-239	1	180	100	155	150	75	80	180	25	2.3	M6	10	7	M8	7.6
0630	100-088-240		210	102	171	190	75	80	205	25	3.2	M6	12	7	M10	12

Condenser for Harmonic Filter

Model	Code No.	Eiguro				D	imensio	ons (mn	n)				Weight
CIMR-DA4A	Code No.	Figure	Α	В	С	D	Е	F	G	Η	H1	_	(kg)
0270	100-088-241	9	438	128	502	398±3	95±2	345	433	80±5	-	M12	27
0370	100-088-242	9	438	128	602	398±3	95±2	345	533	80±5	_	M12	33
0630	100-088-243	10	695	128	582	655±3	95±2	602	513	80±5	60±5	M12	55




Fully-Enclosed Design


An Open-Chassis model can be installed in a fully-enclosed panel.

An open-chassis model in a protective enclosure with the heatsink inside the panel allows for an intake air temperature of up to 50°C. The heatsink can alternatively be mounted outside the enclosure panel. This reduces the amount of heat inside the panel and requires less space for installation. In this case, an intake air temperature of up to 40°C is allowed. Current derating or other steps to ensure cooling are required at 50°C.


· Cooling Design for Fully-Closed Enclosure Panel



 $\cdot \ \text{Mounting the External Heatsink} \\$



· Ventilation Space



If you use a D1000 of 30 kW or larger with a 200 or 400 V class mounted in a panel, provide space for the hoisting eye bolts on both sides of the unit and for main circuit wiring.

Watt Loss Data

D1000 Energy-saving Unit

200 V Class

Model CIMR-DA	2AIIIIIII	0005	0010	0020	0030	0050	0065	0090	0130
Rated Output Ca	apacity kW	5	10	20	30	50	65	90	130
Rated Output Co	urrent A	15	30	61	91	152	197	273	394
	Heatsink	93	167	319	380	666	1193	1616	1918
Heat Loss W	Internal	38	57	101	134	245	464	619	776
VV	Total Heat Loss	131	224	420	514	911	1657	2235	2694

400 V Class

Model CIMR-DA	4A::::::::	0005	0010	0020	0030	0040	0060	0100	0130	0185	0270	0370	0630
Rated Output Ca	apacity kW	5	10	20	30	40	60	100	130	185	270	370	630
Rated Output Co	urrent A	8	15	30	45	61	91	152	197	280	409	561	955
	Heatsink	83	158	314	263	647	1092	1303	1969	2864	2477	3705	6103
Heat Loss W	Internal	37	58	103	109	201	334	467	695	997	1323	1852	3098
VV	Total Heat Loss	120	216	417	372	848	1426	1770	2664	3861	3800	5557	9201

Standard Configuration Devices

200 V Class

Мо	del CIMR	-DA2A[[[[[[]]]]	0005	0010	0020	0030	0050	0065	0090	0130
Hea	at Loss	Harmonic Filter Module	32	55	80	89	122	133	156	265
W		Input AC Reactor 1	80	120	225	270	365	540	665	875

400 V Class


Model CIMR	-DA4A[[[[[[[]]]]	0005	0010	0020	0030	0040	0060	0100	0130	0185	0270	0370	0630
	Harmonic Filter Module	37	57	77	84	96	158	216	272	365	_	_	_
	Input AC Reactor 1	75	100	145	285	290	375	580	610	1065	1205	1305	2610
Heat Loss W	Input AC Reactor 2	_	_	_	_	_	_	_	_	_	365	460	735
VV	Reactor for Harmonic Filter	_	_	_	_	_	-	_	_	_	45	55	90
	Condenser for Harmonic Filter	_	_	_	_	_	_	_	_	_	29	41	111


Attachment for External Heatsink

Additional attachments are required for D1000 with model numbers CIMR-DA2A0005 to 0020, CIMR-DA4A0005 to 0020. The final product will be wider and taller than the unit.

Additional attachments are not required for CIMR-DA2A0030 and above, and CIMR-DA4A0030 and above.

Note: Contact Yaskawa for information on attachments for earlier models.






200 V Class


Model		С	Dimensi	ons (mm	n)		Code No
CIMR-DA2A	W	Н	W1	H1	D1	D2	Code No.
0005	198	329	160	315	112	73.4	EZZ020800C
0010	196	329	160	315	112	/3.4	EZZUZU800C
0020	238	380	192	362	119	76.4	EZZ020800D


400 V Class


Model			imensio	ons (mm	n)		Code No.
CIMR-DA4A	W	Н	W1	H1	D1	D2	Code No.
0005	198	329	160	315	112	73.4	EZZ020800C
0010	190	329	100	313	112	73.4	EZZ020000C
0020	238	380	192	362	119	76.4	EZZ020800D

Panel Modification for External Heatsink









* : Panel opening needed to replace an air filter installed to the bottom of the D1000. The

opening should be kept as small as possible

200 V Class

200 1 01000										O ₁	ocining sino	uid be kept	. as siriali a	o possibic.
Model	Modification						Dim	ensions (mm)					
CIMR-DA2A	Figure	W	Н	W1	W2	W3	H1	H2	H3	H4	H5	А	В	d1
0005		198	329	160	10	9	315	17.5	10.5	7		180	287	M5
0010	1	196	329	160	10	9	315	17.5	10.5	_ ′	_	180	201	CIVI
0020		238	380	192	14	9	362	13	8	9	_	220	341	M6
0030		275	450	220	19.5	8	435	8	7.5	8	7.5	259	419	M6
0050		325	550	260	24.5	8	535	8	7.5	8	7.5	309	519	M6
0065	2	450	705	325	54.5	8	680	12.5	12.5	12.5	12.5	434	655	M10
0090		430	703	323	34.3	0	000	12.5	12.5	12.5	12.5	434	000	IVITO
0130		500	800	370	57	8	773	16	14	17	13	484	740	M12

400 V Class

Model	Modification						Dim	ensions (mm)					
CIMR-DA4A	Figure	W	Н	W1	W2	W3	H1	H2	Н3	H4	H5	А	В	d1
0005		198	329	160	10	9	315	17.5	10.5	7	_	180	287	M5
0010	1	190	329	100	10	9	313	17.5	10.5	_ ′		100	201	IVIS
0020		238	380	192	14	9	362	13	8	9	_	220	341	M6
0030		275	450	220	19.5	8	435	8	7.5	8	7.5	259	419	M6
0040		2/3	450	220	19.5	0	433	0	7.5	0	7.5	259	419	IVIO
0060	2	325	550	260	24.5	8	535	8	7.5	8	7.5	309	519	M6
0100		323	550	200	24.5	0	333	0	7.5	0	7.5	309	319	IVIO
0130		500	800	370	57	8	773	16	14	17	13	484	740	M12
0185		300	800	370	37	0	113	10	14	17	13	404	740	IVIIZ
0270	3	670	1140	440	107	8	1110	19	15	19	15	654	1072	M12
0370] 3	670	1140	440	107	0	1110	19	15	19	15	054	1072	IVIIZ
0630	4	1250	1380	1100	67	8	1345	19	20	19	15	1234	1307	M12

Peripheral Devices and Options

Fusible Disconnect Ground Fault Interrupter, Circuit Breaker (MCCB) Magnetic Contactor Noise Filter Standard Configuration Devices Harmonic Filter Module USB Copy Unit (RJ-45/ USB adapter) Drive Drive Drive Drive

Peripheral Devices

Name	Purpose	Model, Manufacturer	Page
Ground Fault Interrupter (GFI)	Always install a GFI on the power-supply side to protect the power supply system and to prevent an overload at the occurrence of shortcircuit, and to protect the drive from ground faults that could result in electric shock or fire. Note: When a GFI is installed for the upper power supply system, an MCCB can be used instead of a GFI. Choose a GFI designed to minimize harmonics specifically for energy-saving units. Use one GFI per energy-saving unit, each with a current rating of at least 30 mA.	NV series* by Mitsubishi Electric Corporation NS Series* by Schneider Electric	26
Circuit Breaker	Always install a circuit breaker on the power-supply side to protect the power supply system and to prevent an overload at the occurrence of a short-circuit.	NF series* by Mitsubishi Electric Corporation	26
Magnetic Contactor	Interrupts the power supply to the drive. In addition to protecting drive circuitry, a magnetic contactor also prevents damage to a braking resistor if used.		26
Surge Protector	Absorbs the voltage surge from switching of electro- magnetic contactors and control relays. Install a surge protector to the magnetic contactors and control relays as well as magnetic valves and magnetic braking coil.	DCR2 series RFN series by Nippon Chemicon Corporation	26
Noise Filter (Zero Phase Reactor)	Reduces noise from the line that enters into the input power system of energy-saving unit should be installed as close as possible to D1000. Can be used on both the input and output sides.	F6045GB F11080GB by Hitachi Metals, Ltd.	27

^{* :} Recommended by Yaskawa. Contact the manufacturer in question for availability and specifications of non-Yaskawa products.

Options

Name	Purpose	Model, Manufacturer	Page
24 V Power Supply	Provides power supply for the control circuit and option boards. Note: Parameter settings cannot be changed when the drive is operating solely from this power supply.	PS-A10LB (200 V class)	27
USB Copy Unit (RJ-45/ USB compatible plug)	· Can copy parameter settings easily and quickly to be later transferred to another drive. · Adapter for connecting D1000 to the USB port of a PC.	JVOP-181	29
PC Cable	Connect D1000 and PC when using DriveWizard Plus. The cable length must be 3 m or less.	Commercially available USB2.0 A/B cable.	29
LCD Operator	For easier operation when using the optional LCD operator. Allows for remote operation. Includes a Copy function for saving the settings of D1000.	JVOP-180	28
LCD Operator Extension Cable	Cable for connecting the LCD operator.	WV001 : 1 m WV003 : 3 m	28
Attachment for External Heatsink	Required for heatsink installation. Note: Current derating may be needed when using a heatsink.	_	23

Option Cards

Ту	ре	Name	Model	Function	Manual No.
		MECHATROLINK-II Interface	SI-T3	Used for running or stopping the D1000, setting or referencing parameters, and monitoring input current, output voltage, or similar items through MECHATROLINK-II communication with the host	TOBPC73060050 SIEPC73060061
	5			controller.	SIEPC/3000001
	Option Card	CC-Link Interface	Available soon	Used for running or stopping the D1000, setting or referencing parameters, and monitoring input current, output voltage, or similar items through CC-Link communication with the host controller.	_
connector)		DeviceNet Interface	Available soon	Used for running or stopping the D1000, setting or referencing parameters, and monitoring input current, output voltage, or similar items through DeviceNet communication with the host controller.	-
	DeviceNet Available Interface soon PROFIBUS-DP Available soon			Used for running or stopping the D1000, setting or referencing parameters, and monitoring input current, output voltage, or similar items through PROFIBUS-DP communication with the host controller.	_
Built-in Type (connected to		CANopen Interface	Available soon	Used for running or stopping the D1000, setting or referencing parameters, and monitoring input current, output voltage, or similar items through CANopen communication with the host controller.	-
Built-in Ty	Analog Monitor AO-A3		AO-A3	Outputs analog signal for monitoring the output state (input frequency, output voltage etc.) of the D1000. Output resolution: 11 bit signed (1/2048) Output voltage: 0 to 10 Vdc (non-isolated) Terminals: 2 analog outputs	TOBPC73060040
	Monitor Op	Digital Output	DO-A3	Outputs isolated type digital signal for monitoring the run state of the D1000 (alarm signal, during run, etc.) Terminals: 6 photocoupler outputs (48 V, 50 mA or less) 2 relay contact outputs (250 Vac, 1 A or less 30 Vdc, 1 A or less)	TOBPC73060041

Note: 1. Each communication option card requires a separate configuration file to link to the network.

2. The option cards are RoHS compliant.

Peripheral Devices and Options (continued)

Ground Fault Interrupter, Circuit Breaker, Magnetic Contactor

Select these devices according to the model of D1000.




Ground Fault Interrupter [Mitsubishi Electric Corporation]



Circuit Breaker [Mitsubishi Electric Corporation]



Magnetic Contactor [Fuji Electric FA Components & Systems Co., Ltd]



Note: When wiring contactors in parallel, make sure wiring lengths are the same to keep current flow even by installing junctions.

200 V Class


D1000	Ground Fault Interrupter			Circuit Breaker			Magnetic Contactor	
Model CIMR-DA2A[[][[][]]]	Model	Rated Current (A)	Interrupt Capacity (kA) Icu/Ics*1	Model	Rated Current (A)	Interrupt Capacity (kA) Icu/Ics*1	Model	Rated Current (A)
0005	NV32-SV	20	10/10	NF32-SV	20	7.5/7.5	SC-N1	26
0010	NV63-SV	50	15/15	NF63-SV	50	15/15	SC-N2S	50
0020	NV125-SV	100	50/50	NF125-SV	100	50/50	SC-N4	80
0030	NV250-SV	150	85/85	NF250-SV	150	85/85	SC-N6	125
0050	NV250-SV	225	85/85	NF250-SV	225	85/85	SC-N8	180
0065	NV400-SW	300	85/85	NF400-SW	300	85/85	SC-N11	300
0090	NV400-SW	400	85/85	NF400-SW	400	85/85	SC-N12	400
0130	NV630-SW	600	85/85	NF630-SW	600	85/85	SC-N14	600

400 V Class

+00 V Clu55								
D1000	Gro	und Fault In	terrupter	Circuit Breaker			Magnetic Contactor	
Model CIMR-DA4A[[][[][]]]	Model	Rated Current (A)	Interrupt Capacity (kA) Icu/Ics*1	Model	Rated Current (A)	Interrupt Capacity (kA) Icu/Ics*1	Model	Rated Current (A)
0005	NV32-SV	15	5/5	NF32-SV	15	2.5/2.5	SC-4-1	17
0010	NV32-SV	30	5/5	NF32-SV	30	2.5/2.5	SC-N2	32
0020	NV63-SV	50	7.5/7.5	NF63-SV	50	7.5/7.5	SC-N2S	48
0030	NV125-SV	75	25/25	NF125-SV	75	25/25	SC-N4	80
0040	NV125-SV	100	25/25	NF125-SV	100	25/25	SC-N4	80
0060	NV250-SV	150	36/36	NF250-SV	150	36/36	SC-N6	110
0100	NV250-SV	225	36/36	NF250-SV	225	36/36	SC-N8	180
0130	NV400-SW	300	42/42	NF400-SW	300	42/42	SC-N11	300
0185	NV400-SW	400	42/42	NF400-SW	400	42/42	SC-N12	400
0270	NV630-SEW	630	42/42	NF630-SW	630	42/42	SC-N14	600
0370	NV800-SEW	800	42/42	NF800-SEW	800	42/42	SC-N16	800
0630	NS1600H*2	1600	70	NF1600-SEW	1600	85/43	SC-N16×2*3	800*4

- *1 : Icu: Rated ultimate short-circuit breaking capacity Ics: Rated service short-circuit breaking capacity
- *2: NS series by Schneider Electric.
- *3: When two units are connected in parallel.
- *4: Rated current for a single unit.

Surge Protector



[Nippon Chemi-Con Corporation]

Product Line

Periph	eral Dev	Surge Protector	Model	Specifications	Code No.
200 V to 230 V	Large-Capacity Coil		DCR2-50A22E	220 Vac $0.5\mu\text{F+200}\Omega$	C002417
200 V to 240 V	Control Relay	MY2, MY3 [Omron Corporation] MM2, MM4 [Omron Corporation] HH22, HH23 [Fuji Electric FA Components & Systems Co., Ltd]	DCR2-10A25C	250 Vac 0.1 μF+100 Ω	C002482
	380) to 480 V	RFN3AL504KD	1000 Vdc 0.5 μ F+220 Ω	C002630

Noise Filter (Zero Phase Reactor)


Select the zero-phase reactor in accordance with the wire gauge used for ${\rm D}1000.^*$


★: Current values for wire gauges may vary based on electrical codes. The following table lists recommended wire gauges based on Japanese electrical standards and Yaskawa's Normal duty (ND) rating. Contact Yaskawa for details regarding wire and UL standards.

FINEMET Zero-Phase Reactor to Reduce Radio Noise

Note: FINEMET is a registered trademark of Hitachi Metals, Ltd.







Zero phase reactor devices D1000

Standard


All wires $(X,\,Y,\,Z)$ should pass through the four cores of the reactor in series without winding.


Diagram b


Separate each terminal lead for X, Y, and Z in half, passing one half of the wires through a set of four cores and the other half through the other set of four cores as shown.

Diagram c

Dimensions (mm)







Model F6045GB

Model F11080GB

Model F200160PB

200 V Class

D1000	D1000			Noise Filter (Zero Phase Reactor)			
Model CIMR-DA2A[[][[][]]]	Recommended Gauge (mm²)	Model	Code No.	Qty.	Diagram		
0005	2	F6045GB	FIL001098	1			
0010	5.5	F6045GB	FILUU 1096	'	а		
0020	14	F6045GB	FIL001098	4	b		
0030	38	F6043GB	FILUU 1096	4	D		
0050	60	F11080GB	FIL001097	4	h		
0065	80×2P	FIIOOUGB	FILOUTU97	4	Ь		
0090	80×2P	F200160PB	300-001-041	4	b		
0130	100×2P	F200100FB	300-001-041	4	D		

400 V Class

D1000		Noise Filt	er (Zero Phase	React	tor)
Model CIMR-DA4A[[]]	Recommended Gauge (mm²)	Model	Code No.	Qty.	Diagram
0005	1.25	F6045GB	FIL001098	1	а
0010	2	F6045GB	FILOU 1096	'	а
0020	8	F11080GB	FIL001097	1	а
0030	14				
0040	14	F6045GB	FIL001098	4	b
0060	38				
0100	60				
0130	80×2P	F11080GB	FIL001097	4	b
0185	80×2P				
0270	60×2P	F200160PB	300-001-041	4	b
0370	100×2P	F200100PB	300-001-041	4	וט
0630	100×4P	F200160PB	300-001-041	8	С

24 V Power Supply

The 24 V Power Supply Option maintains D1000 control circuit power in the event of a main power outage. The control circuit keeps the network communications and I/O data operational in the event of a power outage. It supplies external power to the control circuit only. Note: Even if a back-up power supply is used for the control circuit, the main circuit must still have power in order to change parameter settings.






4A0270 to 4A0630.

The installed option adds 50 mm to the total width of D1000.
Installed internally for models CIMR-D

Connection Diagram



Model	Code No.
200 V Class: PS-A10LB	PS-A10LB
400 V Class: PS-A10HB	PS-A10HB

Peripheral Devices and Options (continued)

LCD Operator


An LCD operator with a 6-digit display makes it easy to check the necessary information. Includes a copy function for saving drive settings.

Dimensions (mm)

Model	Code No.	
JVOP - 180	100-041-022	








Operator Extension Cable

Enables remote operation.

	Model	Code No.
Γ	WV001 (1 m)	WV001
	WV003 (3 m)	WV003

Note: Do not use this cable for connecting the unit to a PC. Failure to comply may cause damage to the PC.



extension cable



(JVOP-180)

Operator Mounting Bracket

This bracket is required to mount the LED or LCD operator outside an enclosure panel.

Item	Model	Code No.	Installation	Notes
Installation Support Set A	EZZ020642A	100-039-992	M4 × 10 truss head screw M3 × 6 pan head screw min.50	For use with holes through the panel
Installation Support Set B	EZZ020642B	100-039-993	M4 nut M3 × 6 pan head screw	For use with panel mounted threaded studs Note: If weld studs are on the back of the panel, use the Installation Support Set B.

Connecting to a PC

Note: 1. You can also use a commercially


available USB 2.0 cable (with A-B connectors) for the USB cable.

2. No USB cable is needed to copy parameters to other units.

USB Copy Unit (Model: JVOP-181)

Copy parameter settings in a single step, and then transfer those settings to another D1000. Connects to the RJ-45 port on the D1000 and to the USB port on a PC.

Connection



Note: JVOP-181 is a set consisting of a USB copy unit, RJ-45 cable, and USB cable.

Specifications

Item	Specifications	
Port	LAN (RJ-45) Connect to the D1000.	
	USB (Ver.2.0 compatible) Connect to the PC as required.	
Power Supply Supplied from a PC or the D1000.		
Operating System Windows2000/XP		
Memory	Memorizes the parameters for one D1000.	
Dimensions	30 (W)×80 (H)×20 (D) mm	
Accessories	RJ-45 Cable (1 m), USB Cable (30 cm)	


Note: 1. Parameters can only be saved to the D1000 when the voltage class, capacity, control mode, and software version match.

- 2. Requires a driver for the USB copy unit JVOP-181.
 You can download the driver for free from Yaskawa's product and technical information website (http://www.e-mechatronics.com).
- 3. Parameter copy function disabled when connected to a PC.

PC Cable

Cable used to connect the D1000 to a PC with DriveWizard Plus or DriveWorksEZ installed. Use a commercially available USB 2.0 cable (A-B connectors, 3 m max.).

Connection



- Note: 1. DriveWizard Plus is a PC software package for managing parameters and functions in Yaskawa drives and energy-saving units. You can download the driver for free from Yaskawa's product and technical information website (http://www.e-mechatronics.com).
 - 2. Requires USB driver. You can download the driver for free from Yaskawa's product and technical information website (http://www.e-mechatronics.com).

Application Notes

Application Precautions

■ Installation of D1000 Standard Configuration Devices
You must install both D1000 and the D1000 standard
configuration devices.

■ Replacing Previous Models

- If the peripheral devices (i.e., input AC reactors, reactors for harmonic filters, and capacitors for harmonic filters) for previous models (i.e., the VS-656DC3 and VS-656DC5) are used with D1000, abnormal heating may occur. Refer to installation instructions and adjust D1000 accordingly.
- Do not use the D1000 standard configuration devices with the previous models (i.e., VS-656DC3 and VS-656DC5).

■ D1000 Sequence for Power Loss and Harmonic Filter Installation

Always sequence the power supply for D1000 so that the power supply circuit is opened after the operation of D1000 is stopped.

Always install the specified harmonic filter (harmonic filter module) to reduce the impact of voltage surges on other devices when the circuit opens for any unexpected reason during operation.

■ Installing a Breaker or Contactor on the Unit Output (DC) Side

When installing a breaker or contactor on the D1000 side for an emergency shutoff, confirm that the CHARGE indicators on the drive and D1000 are not lit before closing the breaker or contactor on the D1000 output (DC) side. If the power supply is turned on while there is a voltage charge, an overcurrent will flow and the device may be damaged. Always confirm that the breaker or contactor on the D1000 output (DC) side is turned on before applying power to the D1000.

■ Panel Installation

Install D1000 in a clean environment by either selecting an area free of airborne oil mist, corrosive gas, flammable gas, dust, and lint, or install D1000 in a fully-enclosed panel. If you install D1000 in a panel, determine cooling methods and panel dimensions so that the ambient temperature of D1000 and harmonic filter module are within the allowable temperature range. Do not install D1000 on wood or other inflammable materials.

■ Installation Direction

Install D1000 upright on a wall.

■ Interlocks

An interlock is required between D1000 and a drive to stop the drive if D1000 fails or if an error occurs in D1000. It is also necessary to provide a suitable time to restart the drive if it will be restarted for momentary power losses.

Restarting can be timed with the During MC ON signal that is output from the control circuit terminals of D1000.

Create a sequence to turn off the output from the drive with an external base block input to the drive or by a similar means when the During MC ON signal opens. (Refer to *6 in the Standard Connection Diagram.)

Example 1 Not Restarting for Momentary Power Losses
(Coasting to a Stop for Momentary Power Losses)
Connect the During MC ON output from D1000 to the external fault input on the drive.

Use an N.C. input for the external fault input on the drive and set the drive to detect external faults only during operation to prevent an external fault from being detected when the power supply is turned on.

Example 2 Restarting the System for Momentary Power Losses
Change the setting for the external base block
input terminal S8 on the drive from the default
setting of an N.O. contact to an N.C. contact.

Connect the During MC ON output from D1000 to the external base block input on the drive. Set restarting for momentary power losses in the drive.

Note: For V1000/J1000, an external base block is not set in the default settings. Set an external base block (N.C.) for one of the multi-function input terminals.

Example 3 Inputting a Run Commands to the Drive
Always input Run Commands to the drive while
D1000 is operating. You can check the operating
status of D1000 with a During Run 1 signal on a multifunction output. For an example of a drive sequence,
refer to Standard D1000 Connection Diagram.

■ Wiring Check

Do not short the output terminals or apply voltage to output terminals (U/T1, V/T2, W/T3), because this can cause serious damage to D1000 and the harmonic filter module.

Be sure to perform a careful check of all sequence wiring and other connections before turning the power on. Make sure there are no short circuits on the control terminals (+V, AC, etc.), because this could damage D1000.

■ Inspection and Maintenance

Capacitors in D1000 do not immediately discharge after shutting off the power. After shutting off the power, wait at least the amount of time specified on the unit and harmonic filter module before touching any components. Failure to comply may result in injury to personnel from electrical shock. Take proper precautions to prevent burns, because the heatsink of D1000 and the reactors of the harmonic filter module can get very hot during operation. When replacing the cooling fan, shut off the power to D1000 and wait at least 15 minutes to ensure that the heatsink has cooled down.

Before wiring the harmonic filter module or performing any maintenance, shut off the power and then wait at least the amount of time specified on the module to ensure that the heatsink has cooled down before touching any components.

Wiring

Yaskawa recommends using ring terminals on all models. Use only the tools recommended by the terminal manufacturer for crimping.

■ Transporting and Installation

- Do not steam clean D1000 and harmonic filter module.
 During transport, keep the unit from coming into contact with salts, fluorine, bromine, phthalate esters, and other such harmful chemicals.
- Carry any standard configuration device or peripheral device in a method suitable for the weight of the device. If the devices are handled incorrectly, they may fall and result in injury or device damage.

Peripheral Devices

■ When installing a noise filter on the power supply side, use a reactor type noise filter without a capacitor (such as FINEMET zero-phase reactor) and install it after the MCCB on the power supply side. Do not use a noise filter with a built-in capacitor, because the harmonic components may overheat or damage the capacitor. Install a noise filter recommended by Yaskawa.

■ Installing a Ground Fault Interrupter or an MCCB

Be sure to install an MCCB or an ELCB recommended by Yaskawa on the power supply side of D1000 to protect internal circuitry.

The type of MCCB to be selected varies with the power factor on the power supply side (power supply voltage, output frequency, load characteristics, and others). Sometimes a fairly large MCCB may be required due to the affects of the harmonic current on operating characteristics. If you use an ELCB that is not recommended, use one with harmonic suppression that is designed specifically for drives. A malfunction may be caused by high-frequency leakage current, so the rated current of the ELCB must be 30 mA or higher per drive. If a malfunction occurs in an ELCB without any protection, adjust the carrier frequency of the drive, replace the ELCB with one that has countermeasures against high frequency, or use an ELCB which has a rated current of 200 mA or higher per drive.

Select an MCCB or an ELCB with a rated capacity greater than the short-circuit current for the power supply.

■ Magnetic Contactor for Input Power

Use a magnetic contactor (MC) to ensure that power to D1000 can be completely shut off when necessary. The MC should be wired so that it opens when a fault output terminal is activated.

■ Wire Gauges and Wiring Distance

D1000 phase control can be unstable as a result of voltage loss across a long cable running between D1000 and the power supply. Make sure that appropriate wire gauge is used.

The optional LCD operator requires a dedicated cable to connect to D1000. If an analog signal is sent via the input

terminals to operate D1000, make sure that the cable between the analog operator and D1000 is not longer than 50 m, and that the cable is separated from the main circuit wiring. Use reinforced main circuit and reinforced relay sequence circuitry to prevent inductance from surrounding devices.

To use a multi-function analog input, use twisted shielded pair cables and ground the shield. Refer to the Standard Connection diagram for details.

■ Generator Power Supplies

Select a generator capacity that has at least about twice the capacity of the input power supply to D1000. Contact Yaskawa for details.

Set the deceleration time, load, and other factors so that the regenerative power from the motor is 10% or less of the generator capacity.

Connecting a Phase-advance Capacitor or Thyristorcontrolled Device to the Power Supply

A phase-advance capacitor is not required for D1000. Installing a phase-advance capacitor will reduce the power factor.

For a phase-advance capacitor already installed on the same power supply system as D1000, install a series reactor on the phase-advance capacitor to prevent oscillation with D1000.

Contact Yaskawa if any device generating voltage surge or voltage distortion, such as the thyristor controller of the DC motor drive or magnetic agitator, uses the same power supply.

■ Countermeasures for EMC (Radio Noise) and Highfrequency (Harmonic) Leakage Current

Preventive actions are not required for harmonic current, but preventive actions for EMC (radio noise) or harmonic leakage current are required as for a general drive. If there are nearby devices that are easily affected by noise, install a zero-phase reactor as a noise filter. If you install an MCCB or ELCB at the power supply, use an MCCB or ELCB designed for drives. The MCCB or ELCB should have countermeasures for high-

■ Compliance with Harmonic Suppression Guidelines

- A guideline for the reduction of harmonic emissions is available for users whose equipment requires 6.6 kV or more from the power supply system. Refer to the Harmonics Suppression Technical Guideline JEAG 9702-1995 for details.
- · Although D1000 is equivalent to a self-excited, three-phase bridge (K₅=0), that generates no harmonics, note that the harmonics are not completely eliminated.

■ Impact of Power Supply Distortion

frequency leakage current.

When the power supply voltage is distorted or when several devices are connected in parallel to the same power supply, the relative harmonic content becomes larger, because the harmonics of the power supply system enter D1000.

MEMO

Global Service Network



Region	Service Area	Service Location	Service Agency	Telephone/Fax
North America	U.S.A.	Chicago (HQ) Los Angeles San Francisco New Jersey Boston Ohio North Carolina	1) YASKAWA AMERICA INC.	Headquarters ☎ +1-847-887-7000 FAX +1-847-887-7310
	Mexico	Mexico City	2PILLAR MEXICANA. S.A. DE C.V.	+52-555-660-5553 FAX +52-555-651-5573
South America	South America	São Paulo	69YASKAWA ELÉTRICO DO BRASIL LTDA.	+55-11-3585-1100 FAX +55-11-5581-8795
	Colombia	Bogota	OVARIADORES LTD.A.	+57-1-428-4225 FAX +57-1-428-2173
Europe	Europe, South Africa	Frankfurt	9YASKAWA EUROPE GmbH	+49-6196-569-300 FAX +49-6196-569-398
Asia	Japan	Tokyo, offices nationwide	SYASKAWA ELECTRIC CORPORATION (Manufacturing, sales)	+81-3-5402-4502 FAX +81-3-5402-4580
			YASKAWA ELECTRIC ENGINEERING CORPORATION (After-sales service)	+81-4-2931-1810 FAX +81-4-2931-1811
	South Korea	Seoul	SYASKAWA ELECTRIC KOREA CORPORATION	+82-2-784-7844 FAX +82-2-784-8495
			9YASKAWA ENGINEERING KOREA CORPORATION	+82-2-3775-0337 FAX +82-2-3775-0338
	China	Beijing, Guangzhou, Shanghai	●YASKAWA ELECTRIC (CHINA) CO., LTD.	+86-21-5385-2200 FAX +86-21-5385-3299
	Taiwan	Taipei	(1) YASKAWA ELECTRIC TAIWAN CORPORATION	+886-2-2502-5003 FAX +886-2-2505-1280
	Singapore	Singapore		+65-6282-3003 FAX +65-6289-3003
			®YASKAWA ENGINEERING ASIA-PACIFIC PTE. LTD.	+65-6282-1601 FAX +65-6382-3668
	Thailand	Bangkok	[™] YASKAWA ELECTRIC (THAILAND) CO., LTD.	+66-2693-2200 FAX +66-2693-4200
	India	Mumbai	® LARSEN & TOUBRO LIMITED	Headquarters
Oceania	Australia	Sydney (HQ) Melbourne	®ROBOTIC AUTOMATION PTY. LTD.	Headquarters ☎ +61-2-9748-3788 FAX +61-2-9748-3817

DRIVE CENTER (INVERTER PLANT)

2-13-1, Nishimiyaichi, Yukuhashi, Fukuoka, 824-8511, Japan Phone 81-930-25-3844 Fax 81-930-25-4369 http://www.yaskawa.co.jp

YASKAWA ELECTRIC CORPORATION

New Pier Takeshiba South Tower, 1-16-1, Kaigan, Minatoku, Tokyo, 105-6891, Japan Phone 81-3-5402-4502 Fax 81-3-5402-4580 http://www.yaskawa.co.jp

YASKAWA AMERICA, INC. 2121 Norman Drive South, Waukegan, IL 60085, U.S.A. Phone 1-800-YASKAWA (927-5292) or 1-847-887-7000 Fax 1-847-887-7310 http://www.yaskawa.com

YASKAWA ELÉTRICO DO BRASIL LTDA. Avenida Piraporinha 777, Diadema, São Paulo, 09950-000, Brazil Phone 55-11-3585-1100 Fax 55-11-3585-1187 http://www.yaskawa.com.br

YASKAWA EUROPE GmbH

Hauptstrasse 185, 65760 Eschborn, Germany Phone 49-6196-569-300 Fax 49-6196-569-398 http://www.yaskawa.eu.com

YASKAWA ELECTRIC UK LTD.

1 Hunt Hill Orchardton Woods, Cumbernauld, G68 9LF, United Kingdom Phone 44-1236-735000 Fax 44-1236-458182 http://www.yaskawa.co.uk

YASKAWA ELECTRIC KOREA CORPORATION

9F, Kyobo Securities Bldg., 26-4, Yeouido-dong, Yeongdeungpo-gu, Seoul, 150-737, Korea Phone 82-2-784-7844 Fax 82-2-784-8495 http://www.yaskawa.co.kr

YASKAWA ELECTRIC (SINGAPORE) PTE. LTD.

151 Lorong Chuan, #04-02A, New Tech Park 556741, Singapore Phone 65-6282-3003 Fax 65-6289-3003 http://www.yaskawa.com.sg

YASKAWA ELECTRIC (CHINA) CO., LTD.

12F, Carlton Bldg., No.21 HuangHe Road, HuangPu District, Shanghai 200003, China Phone 86-21-5385-2200 Fax 86-21-5385-3299 http://www.yaskawa.com.cn

YASKAWA ELECTRIC (CHINA) CO., LTD. BEIJING OFFICE

Room 1011, Tower W3 Oriental Plaza, No.1 East Chang An Ave., Dong Cheng District, Beijing, 100738, China Phone 86-10-8518-4086 Fax 86-10-8518-4082

YASKAWA ELECTRIC TAIWAN CORPORATION

9F, 16, Nanking E. Rd., Sec. 3, Taipei, 104, Taiwan Phone 886-2-2502-5003 Fax 886-2-2505-1280 http://www.yaskawa-taiwan.com.tw

YASKAWA INDIA PRIVATE LIMITED

#17/A Electronics City, Hosur Road Bangalore 560 100 (Karnataka), India Phone 91-80-4244-1900 Fax 91-80-4244-1901 http://www.yaskawaindia.in



YASKAWA ELECTRIC CORPORATION

In the event that the end user of this product is to be the military and said product is to be employed in any weapons systems or the manufacture thereof, the export will fall under the relevant regulations as stipulated in the Foreign Exchange and Foreign Trade Regulations. Therefore, be sure to follow all procedures and submit all relevant documentation according to any and all rules, regulations and laws that may apply. Specifications are subject to change without notice for ongoing product modifications and improvements.